

Appendix 6 Underground Storage Tank Spill Containment Testing Report Form

TESTING TYPE Installation Repair 12 Month

1. FACILITY INFORMATION		
CERS ID	Test Date	
Facility Name		
Facility Address	City	ZIP Code

2. SERVICE TECHNICIAN INFORMATION	
Company Performing Testing	Phone
Mailing Address	
Service Technician Performing Testing	
Contractor License Number	
ICC Certification	ICC Expiration Date

3. TRAINING AND CERTIFICATIONS	
Manufacturer and Test Equipment Training Certifications	Training Expiration Date

4. TEST PROCEDURE INFORMATION	
Test Procedures Used	Components Tested

5. CERTIFICATION BY SERVICE TECHNICIAN CONDUCTING TEST		
<p><i>I hereby certify that each spill containment was tested in accordance with California Code of Regulations, title 23, division 3, chapter 16, section 2664; that required supporting documentation is attached; and all information contained herein is accurate. I understand that test procedures must be made available upon request by the governing authority.</i></p>		
Service Technician Signature	Date	Total # of Pages

CERS = California Environmental Reporting System, ICC = International Code Council,
ID = Identification

Underground Storage Tank Spill Containment Testing Report Form

6. SPILL CONTAINMENT DETAILS

Test Method Developed by	<input type="checkbox"/> Manufacturer	<input type="checkbox"/> Industry Standard	<input type="checkbox"/> Professional Engineer
Test Type	<input type="checkbox"/> Pressure	<input type="checkbox"/> Vacuum	<input type="checkbox"/> Hydrostatic

Check this box if Appendix 6.1 continuation page is attached.

Tank ID				
Spill Containment Manufacturer:				
Method of Cathodic Protection	<input type="checkbox"/> Nonmetallic <input type="checkbox"/> Other	<input type="checkbox"/> Nonmetallic <input type="checkbox"/> Other	<input type="checkbox"/> Nonmetallic <input type="checkbox"/> Other	<input type="checkbox"/> Nonmetallic <input type="checkbox"/> Other
Is the spill containment minimum capacity five gallons excluding riser volume?	<input type="checkbox"/> Yes <input type="checkbox"/> No*	<input type="checkbox"/> Yes <input type="checkbox"/> No*	<input type="checkbox"/> Yes <input type="checkbox"/> No*	<input type="checkbox"/> Yes <input type="checkbox"/> No*
Method to keep spill containment empty	<input type="checkbox"/> Drain <input type="checkbox"/> Pump <input type="checkbox"/> Other	<input type="checkbox"/> Drain <input type="checkbox"/> Pump <input type="checkbox"/> Other	<input type="checkbox"/> Drain <input type="checkbox"/> Pump <input type="checkbox"/> Other	<input type="checkbox"/> Drain <input type="checkbox"/> Pump <input type="checkbox"/> Other
Spill Containment Test Results	<input type="checkbox"/> Pass <input type="checkbox"/> Fail	<input type="checkbox"/> Pass <input type="checkbox"/> Fail	<input type="checkbox"/> Pass <input type="checkbox"/> Fail	<input type="checkbox"/> Pass <input type="checkbox"/> Fail

Tank ID				
Spill Containment Manufacturer:				
Method of Cathodic Protection	<input type="checkbox"/> Nonmetallic <input type="checkbox"/> Other	<input type="checkbox"/> Nonmetallic <input type="checkbox"/> Other	<input type="checkbox"/> Nonmetallic <input type="checkbox"/> Other	<input type="checkbox"/> Nonmetallic <input type="checkbox"/> Other
Is the spill containment minimum capacity five gallons excluding riser volume?	<input type="checkbox"/> Yes <input type="checkbox"/> No*	<input type="checkbox"/> Yes <input type="checkbox"/> No*	<input type="checkbox"/> Yes <input type="checkbox"/> No*	<input type="checkbox"/> Yes <input type="checkbox"/> No*
Method to keep spill containment empty	<input type="checkbox"/> Drain <input type="checkbox"/> Pump <input type="checkbox"/> Other	<input type="checkbox"/> Drain <input type="checkbox"/> Pump <input type="checkbox"/> Other	<input type="checkbox"/> Drain <input type="checkbox"/> Pump <input type="checkbox"/> Other	<input type="checkbox"/> Drain <input type="checkbox"/> Pump <input type="checkbox"/> Other
Spill Containment Test Results	<input type="checkbox"/> Pass <input type="checkbox"/> Fail	<input type="checkbox"/> Pass <input type="checkbox"/> Fail	<input type="checkbox"/> Pass <input type="checkbox"/> Fail	<input type="checkbox"/> Pass <input type="checkbox"/> Fail

7. COMMENTS

* Check this box if any spill containment has less than 5 gallons capacity and requires replacement.

State Water Resources Control Board Privacy Notice on Collection

Civil Code section 1798.17 requires a Privacy Notice on Collection to be provided when personal information is collected. Individuals have the right to review personal information maintained by State Water Resources Control Board and the Regional Water Quality Control Boards (Water Boards) unless access is exempted by law. You may review your records by contacting the official responsible for maintaining your information below. The State Water Resources Control Board (State Water Board) will not disclose your personal information unless authorized by law. To learn more about the Water Boards Privacy Policy, visit waterboards.ca.gov/privacy.html.

Please do not include any personal information that is not requested.

Authority for Collection of Personal Information

The information on the form is required pursuant to Health and Safety Code, division 20, chapter 6.7, section 25280 et seq. and California Code of Regulations, title 23, division 3, chapter 16, section 2610 et seq. (Underground Storage Tank (UST) Statutes and Regulations). The form may be collected or maintained by the applicable Unified Program Agency, the California Environmental Protection Agency, and the State Water Board consistent with applicable UST Statutes and Regulations.

Principal Purpose for Which the Information Collected is to Be Used

The information will be used to review and ensure compliance with the UST Statutes and Regulations.

Known or Foreseeable Disclosures of the Information

Pursuant to the California Constitution and the Public Records Act, the State Water Board must disclose its records to the public upon request unless otherwise exempted by law.

Consequences of Not Providing Any or All Parts of the Requested Information

All requested information is required unless marked optional. Failure to provide requested information may result in violations of the UST Statutes and Regulations.

Official Responsible for Maintenance of Information

Senior Environmental Scientist Supervisor

Contact Information for Responsible Official

State Water Resources Control Board – Division of Water Quality
1001 I St.

Sacramento, CA 95814

(916) 327-8501

DWQ-PRALiaisons@waterboards.ca.gov